

## Certificate of constancy of performance

Regulation for Construction Products

Certificate No.: 0200-CPR-05681 version 02

Issued by FORCE Certification A/S - EC-notified body number 0200

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

### Power, control and communication cables

Product	Intended use	Class	AVCP system
Category 6 U/UTP 23 AWG 4 Pair Cable LSOH  Part no.: 113-10009104X	Supply of electricity and communication inside buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke	B2 <sub>ca</sub> -s1a,d1,a1	1+

placed on the market under the name or trade mark of:

**Norden Communication UK Ltd**  
**Unit 13 Baker Close, Oakwood Business Park**  
**Clacton-On- Sea**  
**Essex CO15 4BD**  
**United Kingdom**

and produced in the manufacturing plant(s):

**Norden Communication UK Ltd**  
**Manufacturing plant A**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in the Annex ZZ of the standard:

### EN 50575:2014 + A1:2016

under system 1+ for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 2019-01-24 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods, nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by FORCE Certification A/S.

FORCE Certification A/S task No.: 119-21437. Certificate ID No.: 12142.

Date of issue: 2022-01-20

Date of expiry: 2025-01-24



Dennis Andersen  
Certification manager

Extracts from this Product Certificate may only be reproduced with a written permission from FORCE Certification A/S  
This new version of 0200-CPR-05681 is issued due to extension of validity. The previous certificate is withdrawn